

7SG1642 Ohmega 406

Distance Protection Relays

Document Release History

This document is issue 2010/02. The list of revisions up to and including this issue is:
Pre release

2010/02	Document reformat due to rebrand

Software Revision History

--	--	--

The copyright and other intellectual property rights in this document, and in any model or article produced from it (and including any registered or unregistered design rights) are the property of Siemens Protection Devices Limited. No part of this document shall be reproduced or modified or stored in another form, in any data retrieval system, without the permission of Siemens Protection Devices Limited, nor shall any model or article be reproduced from this document unless Siemens Protection Devices Limited consent.

While the information and guidance given in this document is believed to be correct, no liability shall be accepted for any loss or damage caused by any error or omission, whether such error or omission is the result of negligence or any other cause. Any and all such liability is disclaimed.

Contents


1	Basic Schemes.....	3
1.1	Time Stepped Distance.....	3
1.2	Loss of Load	4
1.3	Reach Extension.....	5
2	Schemes Incorporating a Signalling Channel.....	7
2.1	Permissive Underreach.....	7
2.2	Permissive Overreach Zone 1 – POR1.....	8
2.3	Permissive Overreach Zone 2 – POR2.....	9
2.4	Blocked Overreach.....	12

1 Basic Schemes

1.1 Time Stepped Distance.

1.1.1 Scheme Operation

A TIME-STEPPED DISTANCE scheme is normally applied when there is no signalling available between relays. Generally, the Zone 1 elements are set to operate for faults up to 80% of the line length. The Zone 2 elements operate up to 120% of the line length after a time delay. The Zone 3 elements are set with a longer reach than the Zone 2 elements, and often have a degree of reverse reach (i.e. an offset characteristic) to provide a further level of back up protection. The Zone 3 time delay is set to be longer than the Zone 2 time delay.



The disadvantage of such a scheme is that faults in the last 20% of the line are cleared after the Zone 2 time delay. This may be acceptable for lower voltage distribution systems, but for important circuits or higher voltage systems additional schemes are available to improve the tripping of the relay.

1.1.2 Settings

Distance Scheme:

Distance Scheme

TIME-STEPPED

Status Inputs: N/A
 Relay Outputs: N/A

1.2 Loss of Load

1.2.1 Scheme Operation

The Loss of Load protection scheme is used to give faster fault clearance time for an end zone fault (i.e between the Zone 1 boundary and the line end) when there is no signalling channel available. This allows a faster clearance time than the time-delayed Zone 2 elements.

Consider a fault occurring near to the remote end, i.e outside of the Zone 1 reach, but within the line length. In a normal time stepped distance scheme, the remote end relay would trip in Zone 1 time, and the local end relay would trip after the Zone 2 time delay. The Loss of Load scheme monitors the current in the healthy phases and can remove the Zone 2 time delay, speeding up the local end trip, when the remote end trip occurs.

If the relay detects a drop in current in one or two phases below the *Loss of Load Level*, with the current on the remaining phases above this level, it will remove the time delay from zone 2, for a fixed time delay (the *LOL Time Limit*) to allow the relay to trip instantaneously. This will allow the relay to trip more quickly for single or double phase faults, but will not affect operation for three phase faults.

A short time delay (typically 20ms), known as the *Loss of Load Pole Scatter Delay* or the *LOL CB Op Delay* is introduced to prevent the Loss of Load feature picking up during normal breaker operation.

1.2.2 Settings

The Loss Of Load function (LOL) is made active by selecting the scheme in the scheme selection menu. If a conventional scheme is selected and a communications failure occurs then a group setting change could be used to switch the scheme on until the communications is restored.

<i>Distance Scheme</i>	LOSS OF LOAD
<i>LOL Level</i>	0.1..0.9 (0.5x In)
<i>LOL CB Op Delay or LOL Pole Scatter Delay</i>	0..50 (20ms)
<i>LOL Time Limit</i>	0..60000 (40ms)

Status Inputs: N/A
Relay Outputs: **AIDED TRIP, LOSS OF LOAD**

1.3 Reach Extension


This scheme is only available in relays with built-in autoreclose.

1.3.1 Scheme Operation

The Reach Extension is designed to be used in conjunction with an autoreclose system.

The Zone 1 elements within the relay have two settings. The standard Zone 1 settings are set as for the time-stepped distance scheme (i.e. 80% of the total line length). Zone 1 X settings are set to overreach the line length (usually these are set to the same value as the zone 2 setting)

When the reach extension scheme is implemented, the relay will use the extended zone 1 reach for tripping. The relay will trip and attempt to auto-reclose. After the CB has tripped and reclosed, the relay will use the standard (underreaching) Zone 1 reach for tripping. Consider a transient fault (i.e. a fault which is removed by tripping and auto-reclosing) in the last 20 % of the line, as shown in the diagram below. The overreaching Zone 1 will trip and reclose for this fault, and since it is transient, it will be cleared. A permanent fault will be cleared after the Zone 2 time on the second trip. Since the majority of faults are transient in nature, this will allow transient faults to be cleared more quickly.



The disadvantage of this scheme is that since the extended Zone 1 reach is an overreaching Zone, it may operate for faults in the next line section. However, when the relay has reclosed, the Zone 1 reach will be reduced so the relay will trip after the Zone 2 time, allowing the correct relay to trip in Zone 1 after reclosing, if the fault is permanent. Overall this will increase the amount of circuit breaker operations on the system, and thus the amount of circuit breaker maintenance required, but it will improve clearance of transient faults. When a status input assigned *Block Reach Extension* is energised will the relay will use the normal Zone 1 reach.

The extended zone 1 reach will be active regardless of whether the autorecloser is on or out of service. It is advised that the *Block Reach Extension* status input is energised whenever the autorecloser is out of service. If the relay features an internal autorecloser, a normally closed contact should be assigned to Autorecloser in Service and connected back into the "Block Reach Extension" status input.

1.3.2 Settings

Distance Scheme

Z1 Extension

Zone 1 X PF Impedance Reach

Zone 1 X PF Resistance Reach

Zone 1 X EF Impedance Reach

Zone 1 X EF Resistance Reach

REACH EXTENSION

ENABLED

These are the settings used by the relay for the first trip

Status Inputs: **BLOCK REACH EXT.**

Relay Outputs: N/A

2 Schemes Incorporating a Signalling Channel

Where a signalling channel is available between ends, the coverage of the relays can be improved. When these Protection Schemes are used, the Zone 1, 2 and 3 are arranged to trip as in the time stepped distance scheme. In addition to this, the relay is also capable of carrying out what is known as a “Carrier Aided Trip”, where the time delay on one of the Zones is removed when the conditions at the remote end, as indicated by the signalling channel meet certain criteria.

The distance protection signalling schemes use the relay outputs *Signal Send 1* and status input *Signal Received 1* for the signalling channel. It is possible to configure these channels with delay using the settings SS pickup, SS Dropoff and SR Dropoff.

2.1 Permissive Underreach.

2.1.1 Scheme Operation


Typically (as for the time stepped scheme) the Zone 1 is set to 80% of the line length, Zone 2 to 120% of the line length and Zone 3 as delayed back up protection to cover at least the longest adjacent line.

The fault must be in the zone between the two relays (i.e. on the line section) if;

Zone 1 element operates, or

Remote end Zone 1 operates AND local Zone 2 element operates.

This is shown in the diagram below:



The relay is arranged to send a signal when its Zone 1 picks up.

The relay will trip instantaneously for a Zone 1 fault. If a signal is received from the remote end, the time delay will be removed from the Zone 2 element, allowing it to trip instantaneously. The name of the scheme comes from the fact that a Permissive signal is being sent by the Underreaching Zone 1.

Where the signalling equipment has an output which indicates that the signalling channel is out of service, this can be connected to a Status Input called *Carrier Recv Guard*. On energisation of this status input the relay will revert to a time stepped distance scheme.

In this scheme, only a single signalling channel is required for two-way signalling, since if the zone 1 elements at both operate, the permissive signal will not be required (since both ends will trip instantaneously in Zone 1).

The scheme also incorporates an *Unstabilise Relay* status input which can be used for intertripping. Energisation of this status input will initiate a signal send

2.1.2 Settings.

<i>Distance Scheme</i>	PUR
<i>SS Pickup</i>	0..60000 (0ms)
<i>SS Dropoff</i>	0..60000 (1ms)
<i>SR Dropoff</i>	0..60000 (1ms)

Status Inputs: **UNSTABILISE RELAY, CARRIER RECV GUARD**


Relay Outputs: **AIDED TRIP**

2.2 Permissive Overreach Zone 1 – POR1.

2.2.1 Scheme Operation

This scheme differs from the other relay schemes, in that it requires that the Zone 1 element to be set with a time delay. Typically the Zone 1 is set to 120% of the line length, Zone 2 to 120% of the line length and Zone 3 as delayed back up protection to cover at least the longest adjacent line. The Zone 1 time delay is usually set the same as the Zone 2 time delay.

The Zone 1 elements are arranged to overreach and the relay is arranged to send a Permissive signal send when any Overreaching Zone 1 element operates. When a signal is received from the remote end the relay will remove the Zone 1 time delay allowing the relays at both ends of the line to trip after a small time delay for an in-zone fault. Relay operation can be seen the diagram below;



Where the signalling equipment has an output which indicates that the signalling channel is out of service, this can be connected to a Status Input called *Carrier Recv Guard*. On energisation of this status input the relay will revert to a time stepped distance scheme.

Since this scheme does not provide any instantaneous protection zone it is rarely used. POR-2 provides a similar but more comprehensive scheme and is the preferred scheme. This scheme is only included in the relay for compatibility with older relays. CB Echo, Current Reversal Guard and Weak Infeed are equally applicable to POR-1 and POR-2, for a description of these features see the POR-2 section of this document.

2.2.2 Settings

<i>Distance Scheme</i>	POR1
<i>SS Pickup</i>	0..60000 (0ms)
<i>SS Dropoff</i>	0..60000 (1ms)
<i>SR Dropoff</i>	0..60000 (1ms)

Status Inputs: **CARRIER RECV GUARD**

Relay Outputs: **AIDED TRIP**

2.3 Permissive Overreach Zone 2 – POR2.

2.3.1 Scheme Operation

Typically (as for the time stepped and PUR schemes) the Zone 1 is set to 80% of the line length, Zone 2 to 120% of the line length and Zone 3 as delayed back up protection to cover at least the longest adjacent line. Zone 1 has no time delay, Zone 2 has a time delay, and the Zone 3 has a larger time delay.


The fault must be in the region between the two relays (i.e. on the line section) if;

Zone 1 element operates, or

Remote end Zone 2 operates AND local Zone 2 element operates.

This is shown in the diagram below:

The relay is arranged to send a signal when its Zone 2 picks up.



The relay will trip instantaneously for a Zone 1 fault. If a signal is received from the remote end, the time delay will be removed from the Zone 2 element, allowing it to trip instantaneously. The name of the scheme comes from the fact that a Permissive signal is being sent by the Overreaching Zone 2

This scheme may be used if the Zone 1 reach does not give sufficient resistive coverage, and may be useful on short lines. Note that when using POR 2, two signalling channels must be available (one in each direction) since the Zone 2 elements which initiate the signal send will both operate for a fault on the line section.

Where the signalling equipment has an output which indicates that the signalling channel is out of service, this can be connected to a Status Input called *Carrier Recv Guard*. On energisation of this status input the relay will revert to a time stepped distance scheme.

2.3.2 Circuit Breaker Echo.

With the circuit breaker at one end of the line open, there can be no permissive signal from the remote end relay. If a fault occurs near the open circuit breaker (i.e. outside the zone 1 of the remote end relay) this would normally be cleared after the Zone 2 time delay. However, where an overreaching zone is used to provide the permissive signal, the CB Echo feature can accelerate the tripping.


If a permissive signal is received from the remote end AND the local Circuit breaker is open, the relay will send (or “echo”) a signal back to the remote end.

Thus operation of one of the relay Zone 2 elements will initiate a signal send of duration set as *POR CB Echo Pulse Width*. On receipt of a signal from the remote end, if the local circuit breaker is open, the relay will echo the signal back to the remote end relay. This will remove the time delay from the Zone 2 element, allowing tripping after a short time delay.

It should be noted that when the remote end trips, the CB open condition will drive this relay into a CB Echo condition also due to the Signal Receive being present. This is the reason that the Echo is sent as a short duration pulse only. Otherwise the relays will hold each other in a permanent echo condition.


2.3.3 Current Reversal Guard.

Additional logic is required in cases where the reach of Zone 2 elements is set to 150% or more of the line length and a fault has a current source at both ends of the protected line. Where parallel feeders are used, there is a danger that when a circuit breaker is opened a race condition can arise between the drop-off of the signal send line and the pick-up of the local distance elements. Consider a fault at point F on the parallel line system shown below:



Point F is within the Zone 2 forward reach of relay D, so relay D will send a permissive signal to the remote end, relay C. Relay A will detect the fault in Zone 1, and trip instantaneously.

The instantaneous Zone 2 element of Relay A will operate, and send a signal to Relay B. Relay B will see the fault in Zone 2, and when it receives the signal from end A will perform a "Carrier Aided Trip" after a short time delay. Thus, Relay A will trip before Relay B, and when it does, direction of current in the healthy feeder (CD) will reverse.



The Relay D Zone 2 element, which previously operated to send a signal to Relay C will reset when breaker A opens. But the signal receive may remain high at end C due to the propagation delay in the signalling channel. The Zone 2 element of relay C will then pick-up for the fault at F when CB A opens. There is then a race condition at relay C between the drop off of the signal receive from Relay D and the pick-up of Relay C Zone 2 element. If the signal receive element is still present in conjunction with the Zone 2 element, then Relay C will also carry out a "Carrier Aided Trip", for a fault outside its intended zone of protection.

Thus, if the local Circuit Breaker is closed, and a relay has received a permissive signal, but the fault is in the reverse direction, there's a danger of a current reversal trip when current reverses. Thus, a time delay, *POR Current Rev Reset* is introduced for which the permissive signal from relay C will be ignored by the carrier aided scheme following the resetting of a reverse fault detection.

2.3.4 Weak End Infeed.

If one end of the line has little or no source of fault current, the relay may not see enough fault current to cause a trip or accelerate the tripping at the remote end. Weak Infeed logic is used to detect this condition. Weak Infeed can be Enabled and Disabled to switch on the Alarm and the scheme signalling and an independent enable/disable setting is used to allow the issue of a local trip for a Weak Infeed detection. If the relay has not detected a fault in either the forward or reverse direction, and a permissive signal is received from the remote end, AND there is a residual voltage greater than the WI Voltage Level AND the local CB is closed, the relay will alarm a "Weak Infeed" condition and send a permissive signal to the remote end allowing the remote end to carry out a carrier aided trip.

2.3.5 Settings

Distance Scheme

POR2

<i>POR Weak Infeed</i>	DISABLED
<i>POR Weak Infeed Trip</i>	DISABLED
<i>WI Voltage Level</i>	5-85v (54v)
<i>POR CB Echo Pulse Width</i>	0-60000ms (250ms)
<i>POR Current Rev Reset</i>	0-60000ms (200ms)
<i>WI Sig Recv PU Delay</i>	0..60000 (0ms)
<i>SS Pickup</i>	0..60000 (0ms)
<i>SS Dropoff</i>	0..60000 (1ms)
<i>SR Dropoff</i>	0..60000 (1ms)

Status Inputs:

SIGNAL RECEIVE 1
CARRIER RECV GUARD


Relay Outputs:

AIDED TRIP
SIGNAL SEND 1
SIGNAL RECEIVE 1
POR WEAK INFEED

2.4 Blocked Overreach

2.4.1 Scheme Operation

This requires a reverse-locking element to allow the sending of a blocking signal.
The fault must be in the region between the two relays (i.e. on the line section) if;
The overreaching Zone 2 element operates and a reverse locking zone at the remote end has **not** operated.
This can be seen in the diagram below;



When the Zone 2 instantaneous element picks up, the relay waits for a “blocking signal” to be received. If no blocking signal is received during a set time delay (known as the Permissive Trip Time) the relay will carry out a “Carrier Aided Trip”. If, during this time delay, a blocking signal is received, the Zone 2 time delay will remain in place, and the relay will carry out a Zone 2 trip after the Zone 2 Time delay.

If the fault is in the last section of the line (i.e. outside the Zone 1 reach) the Zone 2 element will operate, but the remote end relay Zone 4 element not see the fault. Thus, no blocking signal will be sent, and the relay will carry out a “Carrier Aided Trip” after the *Permissive Trip Time*.

Obviously when applying this scheme the reverse reach of the Zone 4 element must be further than the overreach of the remote end Zone 2 element.

Where the signalling equipment has an output which indicates that the signalling channel is out of service, this can be connected to a Status Input called *Carrier Recv Guard*. On energisation of this status input the relay will revert to a time stepped distance scheme.

The scheme also incorporates an *Unstabilise Relay* status input which can be used for intertripping. Energisation of this status input will initiate a signal send

2.4.2 Settings

<i>Distance Scheme</i>	BOR
<i>Permissive Trip Time</i>	0..60000 (1ms)
<i>SS Pickup</i>	0..60000 (0ms)
<i>SS Dropoff</i>	0..60000 (1ms)
<i>SR Dropoff</i>	0..60000 (1ms)

Status Inputs: **BLOCK MODE INHIBIT, CARRIER RECV GUARD, UNSTABILISE RELAY**

Relay Outputs: N/A