

# ATTESTATION OF CONFORMITY

No. E-12-I-004-EH

Issued to:

SIEMENS AG Österreich  
Ruthnergasse 3  
1210 Viena - Austria

for the product:

TM1703 EMIC  
Type: Controlled station  
Software version: revision 4 (SW module ett0)

With the implemented communication protocol:

## IEC 60870-5-104 ed.2 (IS 2006)

Network Access for IEC 60870-5-101 using standard transport profiles in Standard direction<sup>1</sup> and the EDP IEC60870-5-104 interoperability profile (07-1532 LIGHT PID 104 v1.1)

The product has not been shown to be non-conforming to the specified protocol standard, including the interface requirements.

End-to-End data element tests for the information and control points as described in manufacturer Protocol Implementation Conformance Statement (PICS) have been performed on the product's protocol implementation. Functional tests in controlled mode are performed for the following levels:

- |   |   |
|---|---|
| <ul style="list-style-type: none"><li>• <i>Station initialization</i><sup>1</sup></li><li>• <i>Acquisition of events</i><sup>1</sup></li><li>• <i>General Interrogation</i><sup>1</sup></li><li>• <i>Command transmission</i><sup>1</sup></li><li>• <i>Time synchronisation</i><sup>1</sup></li></ul> | <ul style="list-style-type: none"><li>• <i>Parameter loading</i><sup>1</sup></li><li>• <i>Transmission of integrated totals</i><sup>1</sup></li><li>• <i>File transfer</i><sup>1</sup></li><li>• <i>Test procedure</i></li><li>• <i>PLXIT related</i><sup>1</sup></li></ul> |
|---|---|


The test campaign did not reveal any errors in the product's protocol implementation.

This Attestation is granted on account of tests made at location of Siemens in Viena, Austria and performed with UnIECim 60870-5-104 version 1.23.04 (Mar 2011) running CS104 Test Suite version CS104 V1.36. The results, including remarks and limitations, are laid down in our report no. E-12-I-003-EH.

The tests have been carried out on one single specimen of the product, submitted by Siemens. The Attestation does **not** include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA.

Arnhem, January 13, 2012

M. Adriaansen  
Director Management & Operations Consulting NMEA

  
E. Henriquez  
Test Consultant

<sup>1</sup> IMPORTANT: Remarks apply to the implementation of this function. See the resulting report (Chapter 4) for full details  
Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

**KEMA Nederland B.V.**

Utrechtseweg 310, 6812 AR Arnhem; P.O. Box 9035, 6800 ET Arnhem, The Netherlands.  
Telephone + 31 26 356 91 11, Telefax + 31 26 443 38 43