IF IN DOUBT ASK
DO NOT SCALE




RELAY VIEWED FROM REAR

NOTES

1 TERMINALS RECOMMENDED ARE PRE INSULATED & MUST BE CRIMPED USING APPROVED TOOLING.
AMP PIDG OR PLASTI GRIP FUNNEL ENTRY (RING TONGUE) FOR M4 FIXING STUD.

| SUPPLIER | AMP | CABLE SIZE |
|---|---|---|
| AMP | 342103 | 0.25–1.6 SQ MM |
| AMP | 342143 | 1.0–2.6 SQ MM. |

OR ANY OTHER MANUFACTURERS EQUIVALENT TERMINAL.

2 FOR OUTLINE & DRILLING DRG SEE 2995X10012 (A4).

3 IRIG–B & FIBRE OPTIC CONNECTORS MUST BE DISCONNECTED & FIXING NUTS REMOVED BEFORE WITHDRAWING CONTROLLER MODULE.

VIEW ON REAR OF
VERTICALLY MOUNTED RELAY







Controller Module
(SEE NOTE 3)

No Module Fitted

No Module Fitted

No Module Fitted




I/O 1




P.S.U.

| MODULE LABEL KEY | |
|---|---|
| ANALOGUE MODULE | NOT FITTED |
| INPUT/OUTPUT MODULE | I/O 1 etc |
| P.S.U. & BASIC I/O MODULE | P.S.U. |

| ABBREVIATIONS |
|---|
| CT–CURRENT INPUTS |
| VT–VOLTAGE INPUTS |
| SI–STATUS INPUTS |
| CO–CHANGE OVER OUTPUT CONTACTS |
| NO–NORMALLY OPEN OUTPUT CONTACTS |
| NC–NORMALLY CLOSED OUTPUT CONTACTS |

NOT SUBJECT TO UPDATE ONCE COPIED / PRINTED OR DOWNLOADED

Copyright © 2000 VA TECH Reyrolle Ltd. Hebburn

| ISSUE | DATE | NOTED |
|---|---|---|
| 3 RDW | 18/08/03 | MN513/2440 MM |
| 2 | 05/03/01 | MODULE LABEL & POSTN ADDED MN1/JOB/279 |
| 1 | 26/10/00 | CHANGE |

MATERIAL:

Dimensions in millimetres : Surface texture in micrometres.
Machine where marked ✓
For explanation of dimensions, tolerances, notes etc. see B.S.308.
Limit on untoleranced unmachined dimensions ± _____
Limits on untoleranced machined dimensions to B.S.4500;
i.e. up to 6±0.1; over 30 to 120±0.3; over 315±0.8;
over 6 to 30±0.2; over 120 to 315±0.5;
General unmachined angular tolerance ± _____

Finish:

Treatment:

Title:
TERMINAL I.D. & WIRING FOR IOTA RELAY
(11SI,3CO,10NO) E12 CASE.

VA TECH Reyrolle
AUTOMATION, CONTROL & PROTECTION

Original Scale.
NTS

First used on:
Similar Articles:
Supersedes:

Drg. No.
2761W11005

| DRAWN M GREEN | CHECKED A.LAW | APPROVED RDW | DATE 21/3/01 | IE DN | OPS | PCP | Purch.Spec. | TQ | EAC | CE | STD | A1 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|

SIEMENS
siemens-russia.com